

5B/A100 FLOOR PLAN - 1ST FLOOR  
1/4"=1'-0"


3B/A100 FLOOR PLAN - 2ND FLOOR  
1/4"=1'-0"

NAME	AREA	FUNCTION OF SPACE	AREA PER OCCUPANT	OCCUPANTS	EMERGENCY LIGHTING
WARMING KITCHEN	419	KITCHEN	200	2.1	-
RESTROOM	69	BUSINESS	150	0.5	-
OPEN OFFICES	853	BUSINESS	150	5.7	YES <sup>1</sup>
MECH./STOR.	40	BUSINESS	150	0.3	-
STAIR	125	BUSINESS	150	0.8	-
OFFICES (LOFT)	490	BUSINESS	150	3.3	YES <sup>1</sup>
Sum: 1996				Sum: 13	

**EMERGENCY LIGHTING**

- Emergency illumination shall comply with IBC 1008. The contractor/electrician is responsible for ensuring the following:
  - Refer to the Occupancy Room Schedule to identify spaces requiring emergency lighting.
  - Note that landings outside all major exits also require emergency lighting.
  - Emergency lighting shall provide a minimum of 1 foot-candle throughout all designated spaces.
  - The emergency power system shall supply power for a minimum duration of 90 minutes, using storage batteries, unit equipment, or an on-site generator.
  - Exit signs shall be internally or externally illuminated per IBC 1013.3.
- If required by the Authority Having Jurisdiction (AHJ), the electrical contractor shall submit plans demonstrating compliance with emergency lighting and energy code requirements. Copies of all approval letters must be provided to the architect.

4/A100 ROOM SCHEDULE - OCCUPANCY



Owner: Kenlyn/Marquis German Shepherd Dogs  
11714 N Eastman Rd  
Edgerton, WI 53534-9051  
Kentboylesgsd@aol.com | 608.884.8355

Structural: Ennovation  
PO Box 148  
Orfordville, WI 53576  
kfrey@ennovationbuilt.com | 608.212.6998

Architect: Opening Design  
17 S Fairchild | FL 7  
Madison, WI 53703  
ryan@openingdesign.com | 773.425.6456

FLOOR PLANS  
BARN RELOCATION

389 E HEMENWAY LANE - EDGERTON, WI 53534

A100

This project, like most Opening Design's projects, is open source (Attribution-ShareAlike 4.0 International=CC-BY-SA 4.0)=freely available to any party for future use, assuming the terms such as Attribution and ShareAlike are honored.