

5B/A150 1ST FLOOR RCP  
1/4"=1'-0"

MARK	TYPE	MANUFACTURER	MODEL	DESCRIPTION	TYPE COMMENTS	URL
L1	CAN LIGHT	LITHONIA	LDN4	4" W BRUSH ALUM TRIM	-	<a href="http://tinyurl.com/5ctawayb">http://tinyurl.com/5ctawayb</a>
L1a	CAN LIGHT	LITHONIA	LDN4	4" W BRUSH ALUM - WALL WASH	-	<a href="http://tinyurl.com/5ctawayb">http://tinyurl.com/5ctawayb</a>
L2	2X2 LED FLAT PANEL	LITHONIA	CPX 2X2 3200LM 80 CRI 30K SWL MIN10	-	TBD	TBD
L3	TRACK LIGHTING	JUNO LIGHTING	T620	BLACK	HEAD PER 2FT (SEE PLANS FOR LENGTH OF TRACK)	<a href="http://tinyurl.com/3wmsxhuf">http://tinyurl.com/3wmsxhuf</a>
L4	PENDANT	TBD	TBD	TBD	TBD	TBD
L5	PENDANT	TBD	TBD	TBD	TBD	TBD
L6	WALL SCONCE	STUFF BY ANDREW NEYER	PIPE LIGHT	BLACK	-	<a href="http://tinyurl.com/3dxuause">http://tinyurl.com/3dxuause</a>

5B/A150 LIGHTING SCHEDULE

TYPE MARK	TYPE	WIDTH	HEIGHT	TYPE COMMENTS
DS3684	SINGLE ELIASON DOUBLE ACTION DOOR	3	7	HM FRAME W/ NO STOP (PT - 3)
DS04284	DOUBLE ELIASON DOUBLE ACTION DOOR	3.5	7	HM FRAME W/ NO STOP (PT - 3)

5A/A150 DOOR SCHEDULE - SIMPLE

**LIGHTING NOTES**


- ALL BULBS AS CLOSE TO 3000K (COLOR TEMP) AS POSSIBLE
- ALL BULBS TO BE LED
- EMERGENCY ILLUMINATION PER IBC 1008 (CONTRACTOR/ELECTRICIAN TO ASSURE THE FOLLOWING)
  - SEE OCCUPANCY ROOM SCHEDULE FOR THOSE SPACES THAT NEED EMERGENCY LIGHTING (ILLUMINATION) IN ADDITION, LANDINGS OUTSIDE MAJOR EXITS REQUIRE EMERGENCY LIGHTING AS WELL
  - EMERGENCY LIGHTING TO BE A MINIMUM 1 FOOT CANDLE THROUGHOUT DESIGNATED SPACES
  - THE EMERGENCY POWER SYSTEM SHALL PROVIDE POWER FOR A DURATION OF NOT LESS THAN 90 MINUTES AND SHALL CONSIST OF STORAGE BATTERIES, UNIT EQUIPMENT OR AN ON-SITE GENERATOR
  - EXIT SIGNS SHALL BE INTERNALLY OR EXTERNALLY ILLUMINATED PER IBC 1013.3
- IF THE AUTHORITY HAVING JURISDICTION (AHJ) REQUIRES IT, THE ELECTRICAL CONTRACTOR MUST SUBMIT PLANS TO DEMONSTRATE COMPLIANCE WITH EMERGENCY LIGHTING AND ENERGY CODE REQUIREMENTS. THE CONTRACTOR NEEDS TO PROVIDE THE ARCHITECT WITH COPIES OF ALL APPROVAL LETTERS

3B/A150 LIGHTING NOTES

2A/A150 W1 - FULL HEIGHT PARTITION NOT RATED - BASE  
3"=1'-0"



Architect: OpeningDesign  
17 S Fairchild | FL 7  
Madison, WI 53703  
ryan@openingdesign.com | 773.425.6456



*[Signature]*

REFLECTED CEILING PLAN 02/15/2024  
FK - PEWAUKEE  
1390 CAPITAL DR - PEWAUKEE, WI 53072

A150

This project, like most OpeningDesign's projects, is open source (Attribution-ShareAlike 4.0 International) - freely available to any party for future use, assuming the terms such as Attribution and ShareAlike are honored.