



proposing 2x12's - 24" o.c. Okay?

What would you propose here?

could we augment these rafters with a collar tie, in order to avoid having to locate a structural beam here?

existing 2x6's - 24" o.c.

existing nonstructural ridge board

this part doesn't need to be reinforced

this wall doesn't go up through to the attic.. This is a non bearing wall.

i am assuming this is a structural beam spanning between left/right walls. what is the framing here?

this currently is not a structural rigid beam. Just an existing ridge board.

114' - 8"

5' - 0" SIDE SETBACK

15' - 3 1/4"

EXISTING BUILDING

