

5A/A150 RCP - 1ST FLOOR
3/16"=1'-0"

MARK	TYPE	MANUFACTURER	MODEL	DESCRIPTION	TYPE COMMENTS	URL	COUNT
L1-4	LINEAR LED - DECORATIVE - 4FT	WESTGATE	SCE-SERIES	4FT (BLACK)	-	-	1
L1-6	LINEAR LED - DECORATIVE - 6FT	WESTGATE	SCE-SERIES	6FT (BLACK)	-	-	48
L2	REUSE EXISTING RECESSED CAN	-	-	-	-	-	2
L4	TRACK LIGHTING	JUNO LIGHTING	1620	BLACK	2FT PER HEAD - 12FT TRACK	-	6

4A/A150 LIGHTING SCHEDULE

LIGHTING NOTES


- All bulbs shall be LED with a color temperature as close to 3000K as possible.
- Emergency illumination shall comply with IBC 1008. The contractor/electrician is responsible for ensuring the following:
 - Refer to the Occupancy Room Schedule to identify spaces requiring emergency lighting. Note that landings outside all major exits also require emergency lighting.
 - Emergency lighting shall provide a minimum of 1 foot-candle throughout all designated spaces.
 - The emergency power system shall supply power for a minimum duration of 90 minutes, using storage batteries, unit equipment, or an on-site generator.
 - Exit signs shall be internally or externally illuminated per IBC 1013.3.
- If required by the Authority Having Jurisdiction (AHJ), the electrical contractor shall submit plans demonstrating compliance with emergency lighting and energy code requirements. Copies of all approval letters must be provided to the architect.



Tenant: Play It Again Sports
6674 Odana Rd.
Madison, WI 53719
plasmadison@gmail.com | 608.692.5455

GC: Lake Country Construction Group
161 Horizon Dr
Verona, WI 53593
608.845.1398

Architect: OpeningDesign
17 S Fairchild | FL 7
Madison, WI 53703
ryan@openingdesign.com | 773.425.6456



03.09.2026

REFLECTED CEILING PLAN
PLAY IT AGAIN SPORTS - SUN PRAIRIE
1721 W MAIN ST, SUN PRAIRIE, WI 53590

A150

This project, like most OpeningDesign's projects, is open source (Attribution-ShareAlike 4.0 International=CC-BY-SA 4.0)=freely available to any party for future use, assuming the terms such as Attribution and ShareAlike are honored.